



COUNTY OF LOS ANGELES FIRE DEPARTMENT

FIRE PREVENTION DIVISION

TIRE STORAGE PERMIT REQUIREMENTS

Article 1, section 105 of the Los Angeles County Fire Code states... a permit shall be obtained from the Fire Prevention Division prior to engaging in the following: ... to use an open area or portion thereof to store tires in excess of 1,000 cubic feet (28.3m^3). See Article 1103.3.6. Additional requirements may be applicable.

Individual Piles Tires shall be restricted to individual piles not exceeding 5,000 square feet (464.5 m^2) of continuous area. Piles shall not exceed 50,000 cubic feet (1415.8 m^3) in volume or 10 feet (3048mm) in height.

Separation A clear space of least 40 feet (12.192mm) shall be provided between piles. The clear space shall not contain flammable or combustible material or vegetation. Tire storage shall not be located within 10 feet (3048 mm) of any property line or building and shall not exceed 6 feet (1829 mm) in height when within 20 feet (6096 mm) of any property line or building.

Additional
Requirements _____
2/2003